

Department of
Financial & Management Services

Marycarol C. White
Director



Central Purchasing

T. W. Sawyer, CPPO
Purchasing Agent

September 21, 2004

ADDENDUM NO. 1 - TO ALL OFFERORS

Request for Proposals (RFP) No. 1405

Title: Management Services: Riverwalk Landing Piers – Annual Contract
Dated: September 17, 2004
Date Due: October 26, 2004 @ 5:00 P.M.

Please make the following change(s):

See attached page.

All other terms and conditions remain the same.

Note: A signed acknowledgment of this addendum must be received by this office either prior to the due date and hour or attached to your proposal. Signature on this addendum does not constitute your signature on the original document. The original document must be signed also.

Sincerely,

T. W. Sawyer

T. W. Sawyer, CPPO
Purchasing Agent

Name of Firm

Signature/Title

Date



120 Alexander Hamilton Blvd. • PO Box 532 • Yorktown, Virginia 23690-0532 • (757) 890-3680
TDD (757) 890-3300

Email: tsawyer@yorkcounty.gov



One of the potential offerors on the RFP submitted the following questions and we are providing answers to all registered holders of the RFP. The question submitted follows (answers in *italics*, adjacent to, or below, the question).

Question:.) In the description of the piers, the power pedestals are mentioned but not described. What are the amps configurations on each pedestal (30/50/100)? Is the voltage 208 or 240? Will cable and phone be run to them?

Answer:.) The voltage is 208/120. All of the pedestals will be wired for phone and cable service; although, it has not been decided yet as to whether or not phone and/or cable service will be provided.

Large/Commercial Pier:

3 pedestals with 2-30 amp and 2-50 amp receptacles on each

3 pedestals with 1-100 amp and 2-50 amp receptacles on each

2 pedestals with 4-30 amp receptacles on each

1 pedestal with 4-50 amp

Small Pier:

4 pedestals with 2-30 amp and 2-50 amp receptacles on each

1 pedestal with 4-30 amp receptacles on each